

DATE: 9/22/2003

DATE OF ISSUE: 4/14/2003

PROGRAM ADMINISTRATOR:

DETROIT TESTING LABORATORY, INC.  
7111 E. ELEVEN MILE ROAD  
WARREN MI 48092-2709



**FAA AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM  
CERTIFICATE OF CONFORMANCE**

Name and Address of Manufacturer

EFLA Oy (Ensto)

P.O. Box 77

FIN-06101 Porvoo, Finland

The equipment listed below has been certified in accordance with the procedures contained in AC 150/5345-53, Airport Lighting Equipment Certification Program (ALECP), and the tests contained in AC 150/5345-47A. The certification is based on successful completion of tests and conformance with the requirements of the specification listed in AC 150/5345-47A, and reporting to the Program Administrator the results of such tests, accompanied by related documents.

**L-830 ISOLATION TRANSFORMER  
(AC 150/5345-47A)**

<u>Type</u>	<u>Size</u>	<u>Watts</u>	<u>Amps</u>	<u>Manufacturers Catalog No.</u>
L-830-1	60Hz	30/45	6.6 / 6.6	KR531.1A
L-830-3	60Hz	65	6.6 / 6.6	KR536.1A
L-830-4	60Hz	100	6.6 / 6.6	KR541.1A
L-830-6	60Hz	200	6.6 / 6.6	KR551.1A
L-830-10	60Hz	300	6.6 / 6.6	KR561.1A

1. This equipment requires continuing validation in accordance with the requirements of AC 150/5345-53.
2. Product tested and report issued by:

Report No: 073313H

Date of Report: 4/07/2003

FAA Specification No: AC150/5345-47A

APPROVED FOR CERTIFICATION:

BY:   
David Splane  
Certification Programs Coordinator

DATE: 9/22/03